

	Meridian Fire Department	JPR#	P3
	Driver/Operator Performance Standards	Revision Date: 5/17/2024	Standard: NFPA 1002-17: 5.2.4

Description:	Supplying a 1 ¾" or 2 ½" static load handline for fire attack		
Conditions:	<p>Given an appropriately equipped fire department pumper apparatus, fire hydrant, objective, Officer and FF, position the apparatus to support the deployment of a 1 ¾" and/or 2 ½" static load hose line for fire attack.</p> <p>*Driver/Operator may use either a calculator or pump chart for reference during evolution.</p>		
Time Standard:	N/A	Time Adjustments:	N/A
Time:			

Competencies:	Pass	Fail
1. Acknowledges order from Officer		
2. Spots apparatus as directed (Allowing for efficient hose deployment, building collapse zones, structure access, traffic hazards and placement of other key apparatus).		
3. Sets the parking brake		
4. Ensures transmission is in neutral		
5. Ensures motor is at idle		
6. Safely engages pump (Confirms engagement using speedometer and indicator lights)		
7. Exits cab		
8. Sets wheel chocks		
9. Opens TANK TO PUMP valve (Considers/opens recirculation valve).		
10. Assists FF in breaking selected hose (Returns male coupling to bed or places under tailboard)		
11. Connects selected hose to rear discharge		
12. Confirms FF is ready for water		
13. Opens appropriate discharge valve (slowly filling deployed hose)		
14. Switches to <u>Pressure Control Mode</u> to provide pressure control protection. (As appropriate)		
15. Adjusts throttle to develop and maintain desired pressure for fire stream(s).		
16. Establishes continuous water supply (per JPR-P1 or P1a)		
17. Makes transition to continuous (hydrant) supply		
18. Closes TANK TO PUMP and refills tank during evolution. Tracks static and residual pressures appropriately		
Ability to Apply Hydraulics		
19. Pumps line at proper pressure		

Driver/Operator	Date:
Evaluator	Date: