

	<b>Meridian Fire Department</b>	<b>JPR#</b>	<b>P4</b>
	Driver/Operator Performance Standards	Revision Date: 5/30/2024	Standard: NFPA 1002-17: 5.2.4

<b>Description</b>	Delivery and supply of a deck gun for transitional or defensive fire operations		
<b>Conditions:</b>	<p>Given a deck gun equipped fire department pumper apparatus, fire hydrant, objective, Officer and FF, maneuver and position the apparatus to support the deployment of the deck gun for transitional or defensive for fire operations.</p> <p>*Driver/Operator may use either a calculator or pump chart for reference during evolution.</p>		
<b>Time Standard:</b>	N/A	<b>Time Adjustments:</b>	N/A
		<b>Time:</b>	

Competencies:	Pass	Fail
1. Acknowledges order from Officer		
2. Spots apparatus as directed (Allowing for efficient hose deployment, building collapse zones, structure access, traffic hazards and placement of other key apparatus).		
3. Sets the parking brake		
4. Ensures transmission is in neutral		
5. Ensures motor is at idle		
6. Safely engages pump (Confirms engagement using speedometer and indicator lights)		
7. Exits cab		
8. Sets wheel chocks		
9. Opens <b>TANK TO PUMP</b> valve (Considers/opens recirculation valve).		
10. Assists in establishment of a continuous water supply per JPR-P1/P1a (Min. 100ft of LDH)		
11. Transition to continuous (hydrant) supply		
12. Closes <b>TANK TO PUMP</b> (May refill tank during evolution as necessary). Tracks static and residual pressures appropriately.		
13. Confirms deck gun nozzle and/or tip size.		
14. Confirms CO/FF ready for water. Opens appropriate discharge valve		
15. Switches to <u>Pressure Control Mode</u> to provide pressure control protection.		
16. Adjusts throttle to develop and maintain desired pressure for fire stream(s).		
17. Closes <b>TANK TO PUMP</b> and refills tank during evolution. Tracks static and residual pressures appropriately		
<b>Ability to Apply Hydraulics</b>		
18. Pumps line at proper pressure		

Driver/Operator	Date:
Evaluator	Date: