

	Meridian Fire Department	JPR#	P8
	Driver/Operator Performance Standards	Revision Date: 5/17/2024	Standard: NFPA 1002-17: 5.2.7

Description:	Supply of an FDC (standpipe/sprinkler system) utilizing a forward Lay		
Conditions:	<p>Given an appropriately equipped fire department pumper apparatus, fire hydrant, objective (FDC), Officer and FF, maneuver and position the apparatus to support the supply and operation of an FDC for fireground operations.</p> <p>*Driver/Operator may use either a calculator or pump chart for reference during evolution.</p>		
Time Standard:	N/A	Time Adjustments:	N/A
		Time:	

Competencies:	Pass	Fail
1. Acknowledges order from Officer		
2. Ensures self and all passengers are seated and belted		
3. Awaits "GO" from FF at hydrant		
4. Maneuvers apparatus safely toward objective		
5. Spots apparatus as directed (Allowing for efficient hose deployment, building collapse zones, structure access, traffic hazards and placement of other key apparatus).		
6. Sets the parking brake		
7. Ensures transmission is in neutral		
8. Ensures motor is at idle		
9. Safely engages pump (Confirms engagement using speedometer and indicator lights)		
10. Exits cab		
11. Sets wheel chocks		
12. Opens TANK TO PUMP valve (Considers/opens recirculation valve).		
13. Assists FF in breaking LDH supply line (Secures coupling in bed or places under tailboard)		
14. Connects supply LDH to appropriate intake and makes transition to continuous (hydrant) supply		
15. Closes TANK TO PUMP Tracks static and residual pressures appropriately.		
16. Stretches and connects 2 ½" hose(s) to FDC and appropriate discharge(s), ensuring adequate hose (Secures final coupling in bed or places under tailboard)		
17. Ensures CO/FF is ready for water then opens appropriate discharge valve(s).		
18. Switches to <u>Pressure Control Mode</u> to provide pressure control protection.		
19. Adjusts throttle to develop and maintain desired pressure for fire stream(s).		
Ability to Apply Hydraulics		
16. Pumps line at proper pressure <ul style="list-style-type: none"> - 150psi for supply of a dedicated fire sprinkler system - Appropriate psi for CO confirmed attack line (length, nozzle, elevation, gpm) 		

Driver/Operator	Date:
Evaluator	Date: