

	<b>Meridian Fire Department</b>	<b>JPR#</b>	<b>WT1</b>
	Driver/Operator Performance Standards	Revision Date: 5/30/2024	Standard: NFPA 1002-17: 10.2.1

<b>Description:</b>	Operation of a Water Tender during Attack Pumper nursing operations		
<b>Conditions:</b>	<p>Given an appropriately equipped fire department water tender, fire hydrant, Attack Pumper, Officer and FF, maneuver and position the apparatus to support the supply and operation of an Attack Pumper during a nursing operation.</p> <p>*Driver/Operator may use either a calculator or pump chart for reference during evolution.</p>		
<b>Time Standard:</b>	N/A	<b>Time Adjustments:</b>	N/A
<b>Time:</b>			

Competencies:	Pass	Fail
1. Acknowledges order from Officer		
2. Spots apparatus as directed near Attack Pumper (allowing for efficient hose deployment)		
3. Sets the parking brake		
4. Ensures transmission is in neutral		
5. Ensures motor is at idle		
6. Safely engages pump PTO (Confirms indicator lights)		
7. Exits cab		
8. Sets wheel chocks		
9. Coordinates supply(nurse) line needs with Attack Pumper Engineer (diameter to provide adequate gpm of current and anticipated operations)		
10. Assists Attack Pumper Engineer in supply hose deployment.		
11. Connects Attack Pumper supply to appropriate discharge (On Water Tender).		
12. Ensures Attack Pumper is ready for water then opens appropriate discharge valve(s) (slowly).		
13. Maintains <u>RPM Mode</u> to provide more consistent supply		
14. Adjusts throttle to develop and maintain desired gpm for usage		
<b>Ability to Apply Hydraulics</b>		
15. Pumps line at proper pressure		
- Maintains 20psi residual for Attack Pumper		

Driver/Operator	Date:
Evaluator	Date: