

	<b>Meridian Fire Department</b>	<b>IPS#</b>	<b>SV01</b>
	Individual Performance Standards	Revision Date: 08/05/2024	Standard: NFPA 1001-19: 4.3.14

**Description:** Construction and usage of a catch basin

**Conditions:** Given the necessary tools, equipment, a partner and a defined objective, safely and efficient construct a catch basin for use during salvage and overhaul operations. Full PPE including gloves and SCBA shall be utilized throughout the skill.

\*\*IPS will be successful if completed with a score of 80% or above without any critical failures. \*\*

<b>Time Standard:</b> 4:00	<b>Time Adjustments:</b> +20 sec. per floor above/below grade +20 sec. per side away from "A"	<b>Time:</b> <sup>(1st)</sup>	<b>Time:</b> <sup>(2nd)</sup>
-------------------------------	---	-------------------------------	-------------------------------

Competencies:	1 <sup>st</sup> Attempt	2 <sup>nd</sup> Attempt
1. Acknowledges order from Officer	Pass / Fail	Pass / Fail
2. Secures tools/equipment from apparatus (Time starts)	Pass / Fail	Pass / Fail
3. Confirms partner is ready	Pass / Fail	Pass / Fail
4. Advances toward objective	Pass / Fail	Pass / Fail
5. Opens salvage cover/sheeting over designated area	Pass / Fail	Pass / Fail
6. Folds in corners	Pass / Fail	Pass / Fail
7. Rolls sides (all 4)	Pass / Fail	Pass / Fail
8. Folds remaining corner material back out over rolled edges to lock in corners	Pass / Fail	Pass / Fail
9. Adjusts placement/construction of basin (As necessary)	Pass / Fail	Pass / Fail
10. Reports task completion to Officer (Time Stops)	Pass / Fail	Pass / Fail

\* Indicates a "Critical" component. Failure to complete any critical component constitutes a complete failure of the skill 8/10=80%

**Notes:**

Firefighter:	Date:
Evaluator	Date:
<b>Attempt Outcome:</b>	Pass / Fail <span style="float: right;">Pass / Fail</span>